

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1521:128 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Siemens Building Technologies, Inc, 1000 Deerfield Parkway, Buffalo Grove, IL 60089
Contact: Ferd Orpano (847) 941-6176

DESIGN: Models SIGA-IO-LG, SIGA-MIO-LG Input/Output Modules and SIGA-RM1-LG and SIGA-MRM1-LG Riser Monitor Modules. Models SIGA-IO-LG, SIGA-MIO-LG Input/Output Modules monitors contact type devices. SIGA-RM1-LG and SIGA-MRM1-LG Riser Monitor modules monitors 24Vdc circuits, 25V and 70V audio circuits, and telephone riser signals. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or Edwards, Edwards Systems Technology (EST), model number, electrical rating and UL label.

APPROVAL: Listed as control unit accessories for use with listee's separately listed EST-3 fire alarm control units.

XLF: 7300-1388-241

09-06-2002 IPI



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

SEPTEMBER 6, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager